

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 001

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.19	0.04	0.3	PASS
2	1310	-3.92	0.00	0.3	PASS
3	1310	-4.18	0.03	0.3	PASS
4	1310	-3.61	0.00	0.3	PASS
5	1310	-4.66	0.02	0.3	PASS
6	1310	-3.86	0.00	0.3	PASS
7	1310	-3.77	0.00	0.3	PASS
8	1310	-3.36	0.04	0.3	PASS
9	1310	-4.23	0.00	0.3	PASS
10	1310	-4.04	0.08	0.3	PASS
11	1310	-4.12	0.01	0.3	PASS
12	1310	-4.55	0.02	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 002

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.21	0.07	0.3	PASS
2	1310	-3.88	0.00	0.3	PASS
3	1310	-4.22	0.07	0.3	PASS
4	1310	-3.55	0.00	0.3	PASS
5	1310	-4.69	0.04	0.3	PASS
6	1310	-3.84	0.00	0.3	PASS
7	1310	-3.72	0.00	0.3	PASS
8	1310	-3.55	0.24	0.3	PASS
9	1310	-4.15	-0.11	0.3	PASS
10	1310	-4.14	0.19	0.3	PASS
11	1310	-4.16	0.04	0.3	PASS
12	1310	-4.56	0.02	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 003

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.28	0.13	0.3	PASS
2	1310	-3.83	-0.14	0.3	PASS
3	1310	-4.24	0.09	0.3	PASS
4	1310	-3.53	0.00	0.3	PASS
5	1310	-4.71	0.07	0.3	PASS
6	1310	-3.85	0.00	0.3	PASS
7	1310	-3.76	0.00	0.3	PASS
8	1310	-3.66	0.35	0.3	FAIL
9	1310	-4.14	-0.12	0.3	PASS
10	1310	-4.19	0.23	0.3	PASS
11	1310	-4.17	0.05	0.3	PASS
12	1310	-4.58	0.05	0.3	PASS

Test Report



Company: FIS

Operator: Bob Licari

Test Device: MPO850

Test Date: 10-31-2019

Serial Number: DEMO

Export Time: 01-24-2020 15:23:34

Note:

Record: 004

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.38	0.24	0.3	PASS
2	1310	-3.77	-0.20	0.3	PASS
3	1310	-4.23	0.08	0.3	PASS
4	1310	-3.48	-0.14	0.3	PASS
5	1310	-4.73	0.09	0.3	PASS
6	1310	-3.84	0.00	0.3	PASS
7	1310	-3.78	0.00	0.3	PASS
8	1310	-3.78	0.47	0.3	FAIL
9	1310	-4.04	-0.22	0.3	PASS
10	1310	-4.26	0.30	0.3	FAIL
11	1310	-4.20	0.08	0.3	PASS
12	1310	-4.56	0.03	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 005

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.43	0.29	0.3	PASS
2	1310	-3.70	-0.27	0.3	PASS
3	1310	-4.20	0.05	0.3	PASS
4	1310	-3.40	-0.22	0.3	PASS
5	1310	-4.73	0.09	0.3	PASS
6	1310	-3.85	0.00	0.3	PASS
7	1310	-3.77	0.00	0.3	PASS
8	1310	-3.84	0.53	0.3	FAIL
9	1310	-4.00	-0.26	0.3	PASS
10	1310	-4.28	0.33	0.3	FAIL
11	1310	-4.23	0.11	0.3	PASS
12	1310	-4.57	0.04	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 006

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.49	0.01	0.3	PASS
2	1310	-3.64	0.00	0.3	PASS
3	1310	-4.09	0.00	0.3	PASS
4	1310	-3.23	0.00	0.3	PASS
5	1310	-4.64	0.00	0.3	PASS
6	1310	-3.85	0.01	0.3	PASS
7	1310	-3.74	0.00	0.3	PASS
8	1310	-3.77	0.00	0.3	PASS
9	1310	-3.89	0.00	0.3	PASS
10	1310	-4.29	0.00	0.3	PASS
11	1310	-4.26	0.02	0.3	PASS
12	1310	-4.46	0.00	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 007

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.51	0.02	0.3	PASS
2	1310	-3.62	0.00	0.3	PASS
3	1310	-4.00	-0.12	0.3	PASS
4	1310	-3.17	-0.13	0.3	PASS
5	1310	-4.59	-0.11	0.3	PASS
6	1310	-3.89	0.05	0.3	PASS
7	1310	-3.69	0.00	0.3	PASS
8	1310	-3.69	-0.12	0.3	PASS
9	1310	-3.87	0.00	0.3	PASS
10	1310	-4.25	0.00	0.3	PASS
11	1310	-4.24	0.00	0.3	PASS
12	1310	-4.45	0.00	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 008

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.52	0.03	0.3	PASS
2	1310	-3.56	0.00	0.3	PASS
3	1310	-3.93	-0.19	0.3	PASS
4	1310	-3.13	-0.17	0.3	PASS
5	1310	-4.52	-0.18	0.3	PASS
6	1310	-3.91	0.07	0.3	PASS
7	1310	-3.71	0.00	0.3	PASS
8	1310	-3.58	-0.23	0.3	PASS
9	1310	-3.97	0.05	0.3	PASS
10	1310	-4.21	0.00	0.3	PASS
11	1310	-4.23	0.00	0.3	PASS
12	1310	-4.36	-0.14	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 009

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.50	0.02	0.3	PASS
2	1310	-3.49	-0.15	0.3	PASS
3	1310	-3.85	-0.27	0.3	PASS
4	1310	-3.07	-0.22	0.3	PASS
5	1310	-4.44	-0.25	0.3	PASS
6	1310	-3.89	0.06	0.3	PASS
7	1310	-3.83	0.07	0.3	PASS
8	1310	-3.46	-0.35	0.3	PASS
9	1310	-4.02	0.10	0.3	PASS
10	1310	-4.14	-0.16	0.3	PASS
11	1310	-4.23	0.00	0.3	PASS
12	1310	-4.31	-0.20	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 010

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.47	0.00	0.3	PASS
2	1310	-3.47	-0.18	0.3	PASS
3	1310	-3.81	-0.31	0.3	PASS
4	1310	-3.04	-0.25	0.3	PASS
5	1310	-4.33	-0.36	0.3	PASS
6	1310	-3.86	0.02	0.3	PASS
7	1310	-3.89	0.12	0.3	PASS
8	1310	-3.39	-0.42	0.3	PASS
9	1310	-4.06	0.14	0.3	PASS
10	1310	-4.07	-0.23	0.3	PASS
11	1310	-4.20	0.00	0.3	PASS
12	1310	-4.24	-0.27	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 011

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.39	0.00	0.3	PASS
2	1310	-3.50	0.00	0.3	PASS
3	1310	-3.67	0.00	0.3	PASS
4	1310	-3.05	0.02	0.3	PASS
5	1310	-4.17	0.00	0.3	PASS
6	1310	-3.84	0.00	0.3	PASS
7	1310	-4.02	0.05	0.3	PASS
8	1310	-3.26	0.00	0.3	PASS
9	1310	-4.21	0.08	0.3	PASS
10	1310	-3.95	0.00	0.3	PASS
11	1310	-4.14	0.00	0.3	PASS
12	1310	-4.10	0.00	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 012

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.47	0.04	0.3	PASS
2	1310	-3.54	0.04	0.3	PASS
3	1310	-3.66	0.00	0.3	PASS
4	1310	-3.10	0.07	0.3	PASS
5	1310	-4.19	0.00	0.3	PASS
6	1310	-3.86	0.00	0.3	PASS
7	1310	-4.05	0.08	0.3	PASS
8	1310	-3.22	0.00	0.3	PASS
9	1310	-4.32	0.19	0.3	PASS
10	1310	-3.88	-0.11	0.3	PASS
11	1310	-4.10	0.00	0.3	PASS
12	1310	-4.03	-0.14	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 013

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.53	0.10	0.3	PASS
2	1310	-3.56	0.06	0.3	PASS
3	1310	-3.62	-0.11	0.3	PASS
4	1310	-3.17	0.14	0.3	PASS
5	1310	-4.15	0.00	0.3	PASS
6	1310	-3.88	0.02	0.3	PASS
7	1310	-4.07	0.11	0.3	PASS
8	1310	-3.19	0.00	0.3	PASS
9	1310	-4.38	0.25	0.3	PASS
10	1310	-3.83	-0.16	0.3	PASS
11	1310	-4.08	0.00	0.3	PASS
12	1310	-3.99	-0.18	0.3	PASS

Test Report



Company: FIS

Operator: Bob Licari

Test Device: MPO850

Test Date: 10-31-2019

Serial Number: DEMO

Export Time: 01-24-2020 15:23:34

Note:

Record: 014

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.51	0.09	0.3	PASS
2	1310	-3.62	0.11	0.3	PASS
3	1310	-3.62	-0.11	0.3	PASS
4	1310	-3.21	0.18	0.3	PASS
5	1310	-4.09	-0.12	0.3	PASS
6	1310	-3.87	0.01	0.3	PASS
7	1310	-4.06	0.09	0.3	PASS
8	1310	-3.18	-0.11	0.3	PASS
9	1310	-4.45	0.32	0.3	FAIL
10	1310	-3.76	-0.22	0.3	PASS
11	1310	-4.03	-0.13	0.3	PASS
12	1310	-3.93	-0.24	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 015

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.50	0.07	0.3	PASS
2	1310	-3.67	0.17	0.3	PASS
3	1310	-3.67	0.00	0.3	PASS
4	1310	-3.27	0.24	0.3	PASS
5	1310	-4.02	-0.20	0.3	PASS
6	1310	-3.87	0.01	0.3	PASS
7	1310	-4.05	0.08	0.3	PASS
8	1310	-3.23	0.00	0.3	PASS
9	1310	-4.47	0.35	0.3	FAIL
10	1310	-3.71	-0.28	0.3	PASS
11	1310	-4.00	-0.17	0.3	PASS
12	1310	-3.88	-0.29	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 016

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.40	0.00	0.3	PASS
2	1310	-3.77	0.03	0.3	PASS
3	1310	-3.77	0.04	0.3	PASS
4	1310	-3.37	0.02	0.3	PASS
5	1310	-3.92	0.00	0.3	PASS
6	1310	-3.84	0.00	0.3	PASS
7	1310	-3.97	0.00	0.3	PASS
8	1310	-3.32	0.03	0.3	PASS
9	1310	-4.49	0.00	0.3	PASS
10	1310	-3.62	0.00	0.3	PASS
11	1310	-3.93	0.00	0.3	PASS
12	1310	-3.81	0.00	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 017

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.37	0.00	0.3	PASS
2	1310	-3.83	0.09	0.3	PASS
3	1310	-3.80	0.07	0.3	PASS
4	1310	-3.40	0.05	0.3	PASS
5	1310	-3.90	0.00	0.3	PASS
6	1310	-3.82	0.00	0.3	PASS
7	1310	-3.93	0.00	0.3	PASS
8	1310	-3.38	0.10	0.3	PASS
9	1310	-4.47	0.00	0.3	PASS
10	1310	-3.61	0.00	0.3	PASS
11	1310	-3.90	0.00	0.3	PASS
12	1310	-3.77	0.00	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 018

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.32	-0.14	0.3	PASS
2	1310	-3.91	0.18	0.3	PASS
3	1310	-3.83	0.10	0.3	PASS
4	1310	-3.45	0.11	0.3	PASS
5	1310	-3.87	-0.11	0.3	PASS
6	1310	-3.84	0.00	0.3	PASS
7	1310	-3.87	-0.14	0.3	PASS
8	1310	-3.48	0.19	0.3	PASS
9	1310	-4.43	0.00	0.3	PASS
10	1310	-3.61	0.00	0.3	PASS
11	1310	-3.91	0.00	0.3	PASS
12	1310	-3.68	-0.16	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 019

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.29	-0.17	0.3	PASS
2	1310	-3.99	0.25	0.3	PASS
3	1310	-3.95	0.22	0.3	PASS
4	1310	-3.52	0.18	0.3	PASS
5	1310	-3.80	-0.18	0.3	PASS
6	1310	-3.82	0.00	0.3	PASS
7	1310	-3.82	-0.19	0.3	PASS
8	1310	-3.56	0.27	0.3	PASS
9	1310	-4.39	-0.12	0.3	PASS
10	1310	-3.63	0.00	0.3	PASS
11	1310	-3.89	0.00	0.3	PASS
12	1310	-3.67	-0.17	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 020

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.27	-0.19	0.3	PASS
2	1310	-4.05	0.32	0.3	FAIL
3	1310	-4.00	0.27	0.3	PASS
4	1310	-3.56	0.21	0.3	PASS
5	1310	-3.80	-0.18	0.3	PASS
6	1310	-3.85	0.00	0.3	PASS
7	1310	-3.79	-0.22	0.3	PASS
8	1310	-3.63	0.35	0.3	FAIL
9	1310	-4.37	-0.13	0.3	PASS
10	1310	-3.66	0.01	0.3	PASS
11	1310	-3.86	0.00	0.3	PASS
12	1310	-3.62	-0.23	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 021

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.22	-0.24	0.3	PASS
2	1310	-4.10	0.36	0.3	FAIL
3	1310	-4.06	0.33	0.3	FAIL
4	1310	-3.63	0.29	0.3	PASS
5	1310	-3.82	-0.16	0.3	PASS
6	1310	-3.89	0.04	0.3	PASS
7	1310	-3.82	-0.19	0.3	PASS
8	1310	-3.68	0.39	0.3	FAIL
9	1310	-4.34	-0.16	0.3	PASS
10	1310	-3.70	0.04	0.3	PASS
11	1310	-3.85	0.00	0.3	PASS
12	1310	-3.61	-0.23	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 022

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.21	-0.25	0.3	PASS
2	1310	-4.14	0.41	0.3	FAIL
3	1310	-4.13	0.40	0.3	FAIL
4	1310	-3.62	0.27	0.3	PASS
5	1310	-3.85	-0.13	0.3	PASS
6	1310	-3.90	0.05	0.3	PASS
7	1310	-3.90	-0.11	0.3	PASS
8	1310	-3.73	0.44	0.3	FAIL
9	1310	-4.30	-0.20	0.3	PASS
10	1310	-3.73	0.07	0.3	PASS
11	1310	-3.85	-0.10	0.3	PASS
12	1310	-3.62	-0.23	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 023

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.18	-0.28	0.3	PASS
2	1310	-4.19	0.46	0.3	FAIL
3	1310	-4.19	0.46	0.3	FAIL
4	1310	-3.65	0.31	0.3	FAIL
5	1310	-3.88	0.00	0.3	PASS
6	1310	-3.91	0.06	0.3	PASS
7	1310	-3.93	0.00	0.3	PASS
8	1310	-3.77	0.48	0.3	FAIL
9	1310	-4.28	-0.23	0.3	PASS
10	1310	-3.77	0.11	0.3	PASS
11	1310	-3.85	-0.10	0.3	PASS
12	1310	-3.62	-0.23	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 024

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.15	-0.31	0.3	PASS
2	1310	-4.24	0.50	0.3	FAIL
3	1310	-4.25	0.51	0.3	FAIL
4	1310	-3.67	0.32	0.3	FAIL
5	1310	-3.94	0.00	0.3	PASS
6	1310	-3.91	0.06	0.3	PASS
7	1310	-3.94	0.00	0.3	PASS
8	1310	-3.77	0.48	0.3	FAIL
9	1310	-4.23	-0.28	0.3	PASS
10	1310	-3.81	0.15	0.3	PASS
11	1310	-3.86	0.00	0.3	PASS
12	1310	-3.66	-0.19	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 025

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.13	-0.33	0.3	PASS
2	1310	-4.26	0.52	0.3	FAIL
3	1310	-4.28	0.55	0.3	FAIL
4	1310	-3.69	0.34	0.3	FAIL
5	1310	-3.99	0.01	0.3	PASS
6	1310	-3.88	0.03	0.3	PASS
7	1310	-3.95	0.00	0.3	PASS
8	1310	-3.77	0.48	0.3	FAIL
9	1310	-4.21	-0.30	0.3	PASS
10	1310	-3.86	0.20	0.3	PASS
11	1310	-3.87	0.00	0.3	PASS
12	1310	-3.72	-0.13	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 026

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-3.91	0.00	0.3	PASS
2	1310	-4.08	0.00	0.3	PASS
3	1310	-4.19	0.02	0.3	PASS
4	1310	-3.63	0.03	0.3	PASS
5	1310	-4.07	0.06	0.3	PASS
6	1310	-3.79	0.00	0.3	PASS
7	1310	-3.82	0.00	0.3	PASS
8	1310	-3.65	0.00	0.3	PASS
9	1310	-3.98	0.00	0.3	PASS
10	1310	-3.90	0.01	0.3	PASS
11	1310	-3.54	0.03	0.3	PASS
12	1310	-3.69	0.03	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 027

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-3.92	0.01	0.3	PASS
2	1310	-4.03	0.00	0.3	PASS
3	1310	-4.17	0.00	0.3	PASS
4	1310	-3.66	0.06	0.3	PASS
5	1310	-4.08	0.07	0.3	PASS
6	1310	-3.82	0.01	0.3	PASS
7	1310	-3.79	0.00	0.3	PASS
8	1310	-3.65	0.00	0.3	PASS
9	1310	-4.04	0.00	0.3	PASS
10	1310	-3.96	0.07	0.3	PASS
11	1310	-3.50	0.00	0.3	PASS
12	1310	-3.72	0.06	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 028

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-3.91	0.00	0.3	PASS
2	1310	-4.02	0.00	0.3	PASS
3	1310	-4.15	0.00	0.3	PASS
4	1310	-3.66	0.05	0.3	PASS
5	1310	-4.12	0.11	0.3	PASS
6	1310	-3.78	0.00	0.3	PASS
7	1310	-3.78	0.00	0.3	PASS
8	1310	-3.62	0.00	0.3	PASS
9	1310	-3.96	-0.10	0.3	PASS
10	1310	-4.01	0.12	0.3	PASS
11	1310	-3.52	0.01	0.3	PASS
12	1310	-3.74	0.07	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 029

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-3.91	0.00	0.3	PASS
2	1310	-4.01	0.00	0.3	PASS
3	1310	-4.15	0.00	0.3	PASS
4	1310	-3.64	0.03	0.3	PASS
5	1310	-4.18	0.17	0.3	PASS
6	1310	-3.77	0.00	0.3	PASS
7	1310	-3.75	0.00	0.3	PASS
8	1310	-3.60	0.00	0.3	PASS
9	1310	-3.91	-0.15	0.3	PASS
10	1310	-4.05	0.16	0.3	PASS
11	1310	-3.52	0.01	0.3	PASS
12	1310	-3.78	0.12	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 030

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-3.92	0.01	0.3	PASS
2	1310	-3.97	-0.12	0.3	PASS
3	1310	-4.13	0.00	0.3	PASS
4	1310	-3.64	0.03	0.3	PASS
5	1310	-4.20	0.19	0.3	PASS
6	1310	-3.70	-0.11	0.3	PASS
7	1310	-3.71	-0.13	0.3	PASS
8	1310	-3.54	-0.11	0.3	PASS
9	1310	-3.89	-0.16	0.3	PASS
10	1310	-4.07	0.18	0.3	PASS
11	1310	-3.54	0.03	0.3	PASS
12	1310	-3.85	0.19	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 031

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-3.94	0.03	0.3	PASS
2	1310	-3.96	-0.13	0.3	PASS
3	1310	-4.11	0.00	0.3	PASS
4	1310	-3.61	0.00	0.3	PASS
5	1310	-4.23	0.22	0.3	PASS
6	1310	-3.75	0.00	0.3	PASS
7	1310	-3.69	-0.15	0.3	PASS
8	1310	-3.48	-0.17	0.3	PASS
9	1310	-3.88	-0.17	0.3	PASS
10	1310	-4.11	0.22	0.3	PASS
11	1310	-3.54	0.03	0.3	PASS
12	1310	-3.88	0.22	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 032

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-3.95	0.04	0.3	PASS
2	1310	-3.91	-0.18	0.3	PASS
3	1310	-4.09	0.00	0.3	PASS
4	1310	-3.59	0.00	0.3	PASS
5	1310	-4.25	0.24	0.3	PASS
6	1310	-3.73	0.00	0.3	PASS
7	1310	-3.67	-0.18	0.3	PASS
8	1310	-3.45	-0.20	0.3	PASS
9	1310	-3.88	-0.17	0.3	PASS
10	1310	-4.14	0.25	0.3	PASS
11	1310	-3.55	0.04	0.3	PASS
12	1310	-3.90	0.24	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 033

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-3.98	0.07	0.3	PASS
2	1310	-3.90	-0.19	0.3	PASS
3	1310	-4.07	0.00	0.3	PASS
4	1310	-3.57	0.00	0.3	PASS
5	1310	-4.28	0.27	0.3	PASS
6	1310	-3.74	0.00	0.3	PASS
7	1310	-3.67	-0.17	0.3	PASS
8	1310	-3.40	-0.25	0.3	PASS
9	1310	-3.85	-0.21	0.3	PASS
10	1310	-4.15	0.26	0.3	PASS
11	1310	-3.57	0.06	0.3	PASS
12	1310	-3.92	0.26	0.3	PASS

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 034

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.00	0.09	0.3	PASS
2	1310	-3.86	-0.23	0.3	PASS
3	1310	-4.04	-0.13	0.3	PASS
4	1310	-3.56	0.00	0.3	PASS
5	1310	-4.32	0.31	0.3	FAIL
6	1310	-3.75	0.00	0.3	PASS
7	1310	-3.67	-0.17	0.3	PASS
8	1310	-3.35	-0.30	0.3	PASS
9	1310	-3.82	-0.24	0.3	PASS
10	1310	-4.17	0.28	0.3	PASS
11	1310	-3.61	0.10	0.3	PASS
12	1310	-3.97	0.30	0.3	FAIL

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 035

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.01	0.10	0.3	PASS
2	1310	-3.82	-0.27	0.3	PASS
3	1310	-4.01	-0.16	0.3	PASS
4	1310	-3.53	0.00	0.3	PASS
5	1310	-4.34	0.33	0.3	FAIL
6	1310	-3.75	0.00	0.3	PASS
7	1310	-3.66	-0.19	0.3	PASS
8	1310	-3.32	-0.33	0.3	PASS
9	1310	-3.83	-0.22	0.3	PASS
10	1310	-4.17	0.28	0.3	PASS
11	1310	-3.61	0.10	0.3	PASS
12	1310	-3.99	0.33	0.3	FAIL

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 036

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.17	0.26	0.3	PASS
2	1310	-3.34	-0.75	0.3	PASS
3	1310	-3.75	-0.42	0.3	PASS
4	1310	-3.29	-0.32	0.3	PASS
5	1310	-4.46	0.45	0.3	FAIL
6	1310	-3.74	0.00	0.3	PASS
7	1310	-3.91	0.07	0.3	PASS
8	1310	-3.14	-0.51	0.3	PASS
9	1310	-4.17	0.11	0.3	PASS
10	1310	-4.08	0.19	0.3	PASS
11	1310	-3.86	0.34	0.3	FAIL
12	1310	-4.20	0.53	0.3	FAIL

Test Report



Company: FIS

Operator: Bob Licari

Test Device: MPO850

Test Date: 10-31-2019

Serial Number: DEMO

Export Time: 01-24-2020 15:23:34

Note:

Record: 037

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.17	0.26	0.3	PASS
2	1310	-3.30	-0.79	0.3	PASS
3	1310	-3.71	-0.46	0.3	PASS
4	1310	-3.31	-0.30	0.3	PASS
5	1310	-4.47	0.46	0.3	FAIL
6	1310	-3.76	0.00	0.3	PASS
7	1310	-3.92	0.08	0.3	PASS
8	1310	-3.13	-0.52	0.3	PASS
9	1310	-4.16	0.11	0.3	PASS
10	1310	-4.07	0.19	0.3	PASS
11	1310	-3.86	0.35	0.3	FAIL
12	1310	-4.21	0.55	0.3	FAIL

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 038

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.18	0.28	0.3	PASS
2	1310	-3.33	-0.76	0.3	PASS
3	1310	-3.79	-0.39	0.3	PASS
4	1310	-3.27	-0.34	0.3	PASS
5	1310	-4.45	0.44	0.3	FAIL
6	1310	-3.80	0.00	0.3	PASS
7	1310	-3.95	0.11	0.3	PASS
8	1310	-3.14	-0.51	0.3	PASS
9	1310	-4.10	0.04	0.3	PASS
10	1310	-4.07	0.18	0.3	PASS
11	1310	-3.86	0.35	0.3	FAIL
12	1310	-4.22	0.55	0.3	FAIL

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 039

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.18	0.27	0.3	PASS
2	1310	-3.30	-0.79	0.3	PASS
3	1310	-3.77	-0.41	0.3	PASS
4	1310	-3.28	-0.32	0.3	PASS
5	1310	-4.45	0.44	0.3	FAIL
6	1310	-3.79	0.00	0.3	PASS
7	1310	-3.96	0.11	0.3	PASS
8	1310	-3.14	-0.51	0.3	PASS
9	1310	-4.11	0.06	0.3	PASS
10	1310	-4.05	0.17	0.3	PASS
11	1310	-3.87	0.36	0.3	FAIL
12	1310	-4.20	0.54	0.3	FAIL

Test Report



Company: FIS
Test Device: MPO850
Serial Number: DEMO

Operator: Bob Licari
Test Date: 10-31-2019
Export Time: 01-24-2020 15:23:34

Note:

Record: 040

Polarity: A

FIBER #	Wavelength	dBm	dB	P/F Val(dB)	Pass/Fail
1	1310	-4.18	0.27	0.3	PASS
2	1310	-3.29	-0.80	0.3	PASS
3	1310	-3.75	-0.42	0.3	PASS
4	1310	-3.27	-0.34	0.3	PASS
5	1310	-4.48	0.46	0.3	FAIL
6	1310	-3.79	0.00	0.3	PASS
7	1310	-3.97	0.13	0.3	PASS
8	1310	-3.13	-0.52	0.3	PASS
9	1310	-4.13	0.07	0.3	PASS
10	1310	-4.03	0.14	0.3	PASS
11	1310	-3.88	0.37	0.3	FAIL
12	1310	-4.20	0.54	0.3	FAIL